


On an external flushing arrangement, the flushing liquid, usually different from the material in the pump, comes from an external source. On this \_\_\_\_\_ flush the flushing liquid comes from an external source.

external	
----------	--

On an external flush, the flushing liquid comes from an \_\_\_\_\_ source.

On an external flush, the flushing liquid \_\_\_\_\_ (does/does not) come from the discharge line.

external does not	
----------------------	--




On this seal the flushing liquid \_\_\_\_\_ (does/does not) go into the casing.

does not	
----------	--

On some external flushes, the flushing liquid is circulated and requires an inlet and outlet connection.

An inlet and outlet connection is required when the flushing liquid is \_\_\_\_\_.

circulated	
------------	--



On some external flushes the flushing liquid is not circulated and requires only a single inlet connection.

On this external flush, the flushing fluid \_\_\_\_\_ (would/would not) be circulated.

would not	
-----------	--